



China CEPREI Laboratory

Add: No. 110 Dongguanhuang Rd., Tianhe District,
Guangzhou, Guangdong, 510610, China

Http://www.ceprei.biz

Certificate of Conformity

Number: **E/EC4495181217120**

Date: **2018-12-17**

This Certificate of Conformity implies that the below sample(s) are in accordance with the following test standards under the Electromagnetic Compatibility Directive
(EMC) 2014/30/EU

Product Description : RS232/485/422-CAN(FD)-BUS Intelligent Protocol Converter

Model No. : CANFDCOM-100IE

Rating(s) : 9-48Vdc

Trademark : 

Applicant : Guangzhou ZHIYUAN Electronics Co., LTD.
2 floor, 7 Industrial Zone, Huangzhou Road, Tianhe District,
Guangzhou

Manufacture : Guangzhou ZHIYUAN Electronics Co., LTD.
2 floor, 7 Industrial Zone, Huangzhou Road, Tianhe District,
Guangzhou

Factory : Guangzhou Zhiyuan Electronics Co., Ltd. manufacturing center
Buildings of Guangzhou Light Industry Red Cotton Industrial Park,
46 Xinye Road, Yonghe Economic Development Zone,
Whampoa District, Guangzhou

Test standards : EN55032:2015/AC:2016-07 EN55024:2010/A1:2015
EN 61000-3-2:2014 EN61000-3-3:2013





This Certificate of Conformity is only valid in conjunction with the test report(s) below.

Test report No. : E1810CE8888-00158



Yang Lin (杨 林)
Director



TEST REPORT	
EMC of Information technology equipment	
Report reference No	E1810CE8888-00158
Date of issue	Dec. 6th, 2018
Total number of pages	21
Applicant's Name	Guangzhou ZHIYUAN Electronics Co., LTD.
Address	2 floor, 7 Industrial Zone, Huangzhou Road, Tianhe District, Guangzhou
Manufacture's Name	Guangzhou ZHIYUAN Electronics Co., LTD.
Address	2 floor, 7 Industrial Zone, Huangzhou Road, Tianhe District, Guangzhou
Factory's Name	Guangzhou Zhiyuan Electronics Co., Ltd. manufacturing center
Address	Buildings of Guangzhou Light Industry Red Cotton Industrial Park, 46 Xinye Road, Yonghe Economic Development Zone, Whampoa District, Guangzhou
Testing Laboratory Name	China CEPREI Laboratory
Address	No.110 Dongguan Zhuang Rd., Tianhe District, Guangzhou, Guangdong, 510610, China
Testing location	China CEPREI Laboratory
Test specification	
Standard	EN55032:2015/AC:2016-07 EN55024:2010/A1:2015 EN 61000-3-2:2014 EN61000-3-3:2013
Test procedure	Entrusted Test
Procedure deviation	N/A
Non-standard test method ...	N/A
Test Report Form	
Test Report Form No.	EMC/CE-IT/10-10
TRF originator	CEPREI
Master TRF	Dated 2010-10
This report is based on a blank test report that was prepared by China CEPREI Laboratory using information obtained from the TRF originator (see below).	
Copyright reserved to China CEPREI Laboratory.	
Test item description	RS232/485/422-CAN(FD)-BUS Intelligent Protocol Converter
Trademark	
Model and/or type reference	CANFDCOM-100IE
Rating(s):	9-48Vdc
Test items particulars:	N/A
Tested by (printed name and signature)	Zhou Rupai (周汝派) 
Reviewed by (printed name and signature)	Yu Haitao (余海涛) 
Approved by (printed name and signature)	Chen Hui (陈辉) 

Test case verdicts

Test case does not apply to the test object.....: N/A
Test item does meet the requirement.....: P(Pass)
Test item does not meet the requirement.....: F(Fail)

Testing

Date of receipt of test item: 2018.10.24
Date(s) of performance of test.....: 2018.10.24-2018.10.31

General remarks

This report shall not be reproduced, except in full, without the written approval of the testing laboratory.

The test results presented in this report relate only to the item(s) tested.

Throughout this report a point is used as the decimal separator.

Summary of Testing and Conclusions

The sample(s) tested complies with the standards of EN55032:2015/AC:2016-07, EN55024:2010/A1:2015, EN 61000-3-2:2014, EN61000-3-3:2013.

General product information:

- (1) All EMC tests are carried on model CANFDCOM-100IE.
- (2) According to the manufacturer's specification, CAN cables support communication on cable lengths greater than 3m.
- (3) The maximum working frequency of EUT is not above 108MHz.
- (4) EUT is class A equipment and is used in coal mine remote communication, PLC equipment networking, CAN(FD) teaching application remote communication, CAN(FD) industrial automation control system, intelligent building control data broadcasting system and other CAN(FD) bus application systems.

EMC Standards Compliance List / Test Summary:

Electromagnetic Emissions			
Test Item	Class	Standard	Result
Conducted Emissions from the AC mains power ports	/	/	N/A
Asymmetric Mode Conducted Emissions	/	/	N/A
Conducted Differential Voltage Emissions	/	/	N/A
Radiated Emission at frequencies up to 1GHz	A	EN55032:2015/AC:2016-07	Pass
Radiated Emission at frequencies above 1GHz	/	/	N/A
Radiated Emission from FM receivers	/	/	N/A
Harmonic Current Emission	/	/	N/A
Voltage fluctuation and flicker	/	/	N/A

Electromagnetic Immunity				
Test Item	Performance Criteria	Standard	Test Level	Result
Electrostatic Discharge Immunity	B	EN55024:2010/A1:2015	4 kV (Contact Discharge) 8 kV (Air discharge)	Pass
Electrical Fast Transient/Burst Immunity	B	EN55024:2010/A1:2015	0.5kV (peak)- Input DC power port 0.5kV(peak)- signal port 5/50 Tr/Th ns 5kHz Repetition frequency	Pass
Radio-frequency Electromagnetic Fields Immunity	A	EN55024:2010/A1:2015	80-1000 MHz 3 V/m (unmodulated, r.m.s) 80 % AM (1kHz)	Pass
Radio-frequency Conducted Disturbance Immunity	A	EN55024:2010/A1:2015	Input DC power port and signal port: 0.15-80 MHz 3 V (unmodulated, r.m.s) 80% AM (1kHz)	Pass
Surge immunity	B	EN55024:2010/A1:2015	1.2/50 (8/20) Tr/Th μ s 0.5 kV line to earth(ground)	N/A
Voltage dips, short interruptions immunity	B/C	EN55024:2010/A1:2015	>95% reduction 0.5 periods 30% reduction 25 periods >95% reduction 250 periods	N/A
Power-frequency magnetic field immunity	A	EN55024:2010/A1:2015	50 Hz 1 A/m (r.m.s)	Pass

The test results of the EN55024 are classified into four groups:

- A----Normal performance within the specification limits;
- B----Temporary degradation or loss of function or performance which is self-recoverable;
- C----Temporary degradation or loss of function or performance which requires operator intervention or system reset;
- D----Degradation or loss of function which is not recoverable due to damage of equipment (components) or software, or loss of data.

TABLE OF CONTENTS


EMC Standards Compliance List / Test Summary:	3
TABLE OF CONTENTS	4
Section 1 General Information	5
1.1 Introduction	5
1.2 EUT General and Technical Descriptions	5
1.3 Support Equipment(s) and Test Configuration	5
1.3.1 Details of Support Equipment(s)	5
1.3.2 Working State of EUT	5
1.3.3 Block Diagram of Test Configuration.....	5
1.4 EUT Photographs.....	6
Section 2 Electromagnetic Emissions	9
2.1 Radiated Emission at frequencies up to 1GHz	9
2.1.1 Test Information	9
2.1.2 Measurement Equipments	9
2.1.3 Test Data.....	9
2.1.4 Test Curves	10
2.1.5 Test Setup	11
Section 3 Electromagnetic Immunity	12
3.1 Electrostatic Discharge Immunity.....	12
3.1.1 Electrostatic Discharge Immunity Test Information.....	12
3.1.2 Measurement Equipment Used for Electrostatic Discharge Immunity	12
3.1.3 Test Data.....	12
3.1.4 Test Setup	13
3.2 Electrical Fast Transient/Burst Immunity.....	14
3.2.1 Electrical Fast Transient/Burst Immunity Test Information	14
3.2.2 Measurement Equipment Used for Electrical Fast Transient/Burst Immunity test.....	14
3.2.3 Test Data.....	14
3.2.4 Test Setup	15
3.3 Radio-frequency Electromagnetic Fields Immunity	16
3.3.1 Radio-frequency Electromagnetic Fields Immunity Test Information	16
3.3.2 Measurement Equipment Used for Radio-frequency Electromagnetic Fields Immunity Test.....	16
3.3.3 Test Data.....	16
3.3.4 Test Setup	17
3.4 Radio-frequency Conducted Disturbance Immunity.....	18
3.4.1 Radio-frequency Conducted Disturbance Immunity test information.....	18
3.4.2 Measurement Equipment Used for Radio-frequency Conducted Disturbance Immunity test	18
3.4.3 Test Data.....	18
3.4.4 Test Setup	19
3.5 Power-frequency Magnetic Fields Immunity	20
3.5.1 Magnetic Fields Test Information	20
3.5.2 Measurement Equipment Used for Magnetic Fields test.....	20
3.5.3 Test Data.....	20
3.5.4 Test Setup	21

Section 1 General Information

1.1 Introduction

This report documents the emission and immunity test results for the RS232/485/422-CAN(FD)-BUS Intelligent Protocol Converter.

1.2 EUT General and Technical Descriptions

EUT Name:	RS232/485/422-CAN(FD)-BUS Intelligent Protocol Converter
EUT Model:	CANFDCOM-100IE
EUT Trademark:	
Input Voltage:	9-48Vdc
Input Frequency:	/
Input Current:	/
Power Cable Description:	/
Other Cables Description:	/
I/O Ports:	RS232 port, CAN port
Function(s) Description:	/
Accessories information:	/

1.3 Support Equipment(s) and Test Configuration

1.3.1 Details of Support Equipment(s)

Description	Manufacturer	Model No.	Connection	Working state
Notebook PC	Acer	Aspire E1-410G	USB port	Normal
Computer	/	ZY-IT-PC0058	USB port	Normal
CAN Interface Card	ZLG	USBCAN-8E-U	CAN port	Normal
LCD	DELL	E173FPb	VGA port	Normal

1.3.2 Working State of EUT

1. Power Supply of EUT: 12Vdc 0.15A
2. EUT Status: Data Transmission

1.3.3 Block Diagram of Test Configuration

/


1.4 EUT Photographs

RS232/485/422-CAN(FD)-BUS Intelligent Protocol Converter
CANFDCOM-100IE



9-48Vdc




Marking plate label



Continued



Continued



/

Section 2 Electromagnetic Emissions

2.1 Radiated Emission at frequencies up to 1GHz

2.1.1 Test Information

Temperature:	24°C	Humidity:	60% RH
ATM Pressure:	110.0kPa	Grounding:	Grounded
Test Voltage:	12Vdc	Classification:	CLASS A
Tested by:	Zhou Rupai	Date of test:	2018.10.24
Test Reference:	EN55032:2015/AC:2016-07		
Results:	PASS		

2.1.2 Measurement Equipments


Test Equipment	Manufacturer	Model	Serial No.	Last Cal.	Cal. Due
Anechoic Chamber	EMCT	EMCT-10	7561990029	2018.06.08	2019.06.07
Wideband Receiving Antenna	TDK	HLP-2006C	130884	2018.06.08	2019.06.07
EMI Test Receiver	R&S	ESCI	101020	2018.06.08	2019.06.07
Dual DC Power Supply	CEPREI	6139B	1501LH05	2018.06.08	2019.06.07

2.1.3 Test Data


Horizontal					
No.	Frequency (MHz)	Corrected QP Level Db ($\mu\text{V}/\text{m}$)	10 Meter Limits Db ($\mu\text{V}/\text{m}$)	Angle of Turner (degree)	Height of Tower (cm)
1	47.9	31.3	40	335	400
2	95.9	30.9	40	306	300
3	215.7	38.0	40	128	300
4	263.7	41.2	47	170	300
5	311.7	34.9	47	245	300
6	624.1	37.5	47	203	100
Vertical					
No.	Frequency (MHz)	Corrected QP Level Db($\mu\text{V}/\text{m}$)	10 Meter Limits Db ($\mu\text{V}/\text{m}$)	Angle of Turner (degree)	Height of Tower (cm)
1	47.9	35.5	40	334	200
2	111.9	28.1	40	352	100
3	167.7	28.8	40	212	100
4	215.7	36.9	40	356	100
5	240.0	40.6	47	345	100
6	624.1	35.9	47	325	300

Note: The Corrected QP Level included The Cable attenuation and The Antenna Factor.

2.1.4 Test Curves




Horizontal Radiated Emission Plot (Peak, Max Hold Mode)



Vertical Radiated Emission Plot (Peak, Max Hold Mode)

Note: The Curves included The Cable attenuation and The Antenna Factor.

2.1.5 Test Setup



Radiated Emission at frequencies up to 1GHz Test Set-Up – Front View

/

Section 3 Electromagnetic Immunity

3.1 Electrostatic Discharge Immunity

3.1.1 Electrostatic Discharge Immunity Test Information

Temperature:	22°C	Humidity:	55%
ATM Pressure:	100.5 kPa	Grounding:	Grounded
Test Voltage:	12Vdc		
Tested by:	Zhou Rupai	Date of test:	2018.10.31
Test Reference:	EN55024:2010/A1:2015		
Results:	Pass		

3.1.2 Measurement Equipment Used for Electrostatic Discharge Immunity

Test Equipment	Manufacturer	Model	Serial No.	Last Cal.	Cal. Due
ESD Generator	SCHAFFNER	NSG 438	338	2018.03.08	2019.03.07
AC and DC power supply	KIKUSUI	PCR500M	TC001153	2018.06.08	2019.06.07

3.1.3 Test Data

Test Point	Test Voltage (Kv)				Discharge type	Repetition Rate Hz	Number Of Discharge at each polarity	EUT performance comply to criteria	Result
	2 +/-	4 +/-	8 +/-	15 +/-					
HCP	P/P	P/P	/	/	Contact discharge	1Hz	10	A	Pass
VCP	P/P	P/P	/	/	Contact discharge	1Hz	10	A	Pass
Metal shell	P/P	P/P	/	/	Contact discharge	1Hz	10	A	Pass
Metal port	P/P	P/P	/	/	Contact discharge	1Hz	10	A	Pass
Metal screw	P/P	P/P	/	/	Contact discharge	1Hz	10	A	Pass
Indicator light	P/P	P/P	P/P	/	Air discharge	1Hz	10	A	Pass

The performance criteria are classified into four groups:


A ---- Normal performance within the specification limits;

B ---- Temporary degradation or loss of function or performance which is self-recoverable;

C ---- Temporary degradation or loss of function or performance which requires operator intervention or system reset;

D ---- Degradation or loss of function which is not recoverable due to damage of equipment (components) or software, or loss of data.

3.1.4 Test Setup



Electrostatic Discharge Immunity Test Set-Up –Front View

/

3.2 Electrical Fast Transient/Burst Immunity

3.2.1 Electrical Fast Transient/Burst Immunity Test Information

Temperature:	22°C	Humidity:	55%
ATM Pressure:	100.5 kPa	Grounding:	Grounded
Test Voltage:	12Vdc		
Tested by:	Zhou Rupai	Date of test:	2018.10.31
Test Reference:	EN55024:2010/A1:2015		
Results:	Pass		

3.2.2 Measurement Equipment Used for Electrical Fast Transient/Burst Immunity test

Test Equipment	Manufacturer	Model	Serial No.	Last Cal.	Cal. Due
Comprehensive immunity test instrument	TESEQ	NSG3060	2112	2018.06.08	2019.06.07
AC and DC power supply	KIKUSUI	PCR500M	TC001153	2018.06.08	2019.06.07
EFT Coupling Clamp	TESEQ	CDN3425	1847	2018.06.08	2019.06.07

3.2.3 Test Data

Injected position	Waveform (ns)	Voltage peak (Kv) Power port PE				Repetition rate (kHz)	Test time at each polarity (s)	EUT performance comply to criteria	Result
		0.5	1	2	4				
		+/-	+/-	+/-	+/-				
Positive Input DC Power Port	5/50	P/P	/	/	/	5	60+60	A	Pass
Negative Input DC Power Port	5/50	P/P	/	/	/	5	60+60	A	Pass
PE	5/50	P/P	/	/	/	5	60+60	A	Pass
Positive Input DC Power Port + Negative Input DC Power Port	5/50	P/P	/	/	/	5	60+60	A	Pass
Positive DC Input Power Port + PE	5/50	P/P	/	/	/	5	60+60	A	Pass
Negative DC Input Power Port + PE	5/50	P/P	/	/	/	5	60+60	A	Pass
Positive DC Input Power Port + Negative Input DC Power Port + PE	5/50	P/P	/	/	/	5	60+60	A	Pass
CAN Port	5/50	P/P	/	/	/	5	60+60	A	Pass

The performance criteria are classified into four groups:


A ---- Normal performance within the specification limits;

B ---- Temporary degradation or loss of function or performance which is self-recoverable;


C ---- Temporary degradation or loss of function or performance which requires operator intervention or system reset;

D ---- Degradation or loss of function which is not recoverable due to damage of equipment (components) or software, or loss of data.

3.2.4 Test Setup



Electrical Fast Transient/Burst Immunity Test Input DC Power Port Set-Up –Front View



Electrical Fast Transient/Burst Immunity Test Signal Port Set-Up –Front View

3.3 Radio-frequency Electromagnetic Fields Immunity

3.3.1 Radio-frequency Electromagnetic Fields Immunity Test Information

Temperature:	22°C	Humidity:	55%
ATM Pressure:	100.5 kPa	Grounding:	Grounded
Test Voltage:	12Vdc	Tested Range:	80MHz to 1000MHz
Tested by:	Zhou Rupai	Date of test:	2018.10.31
Test Reference:	EN55024:2010/A1:2015		
Results:	Pass		

3.3.2 Measurement Equipment Used for Radio-frequency Electromagnetic Fields Immunity Test

Test Equipment	Manufacturer	Model	Serial No.	Last Cal.	Cal. Due
Signal Generator	R&S	SMB 100A	102984	2018.06.08	2019.06.07
RF power Amplifier	AR	500W1000A	326103	2018.06.08	2019.06.07
Anechoic Chamber	EMCT	EMCT-3	7561990030	2018.06.08	2019.06.07
Wideband Receiving Antenna	R&S	HL562	100644	2018.06.08	2019.06.07
AC and DC power supply	KIKUSUI	PCR500M	TC001153	2018.06.08	2019.06.07
Electric Field Probe	HOLADAY	HI-6153	82913	2018.06.08	2019.06.07

3.3.3 Test Data

Frequency Range (MHz)	Strength (V/m)	1kHz AM Mod. %	EUT Tuned degree	EUT performance comply to criteria	Result
80~1000	3	80	0°	A	Pass
80~1000	3	80	90°	A	Pass
80~1000	3	80	180°	A	Pass
80~1000	3	80	270°	A	Pass

Note:

The performance criteria are classified into four groups:


A ---- Normal performance within the specification limits;

B ---- Temporary degradation or loss of function or performance which is self-recoverable;

C ---- Temporary degradation or loss of function or performance which requires operator intervention or system reset;

D ---- Degradation or loss of function which is not recoverable due to damage of equipment (components) or software, or loss of data.

3.3.4 Test Setup



Radio-frequency Electromagnetic Fields Immunity Test Set-Up –Front View

/

3.4 Radio-frequency Conducted Disturbance Immunity

3.4.1 Radio-frequency Conducted Disturbance Immunity test information

Temperature:	22°C	Humidity:	55%
ATM Pressure:	100.5 kPa	Grounding:	Grounded
Test Voltage:	12Vdc	Tested Range:	0.15MHz to 80MHz
Tested by:	Zhou Rupai	Date of test:	2018.10.31
Test Reference:	EN55024:2010/A1:2015		
Results:	Pass		

3.4.2 Measurement Equipment Used for Radio-frequency Conducted Disturbance Immunity test

Test Equipment	Manufacturer	Model	Serial No.	Last Cal.	Cal. Due
EM TEST	EM	CWS 500C	0202-04	2018.06.08	2019.06.07
EM TEST CDN	EM	M3	030203	2018.06.08	2019.06.07
Dual DC Power Supply	CEPREI	6139B	1501LH05	2018.06.08	2019.06.07
Conduction Immunity Electromagnetic Injection Clamp	Liithi	EM101	35607	2018.06.08	2019.06.07

3.4.3 Test Data

Injected position	Frequency Range (MHz)	Strength (r m s) (unmodulated)	1kHz AM Mod. %	EUT performance comply to criteria	Result
Input DC Power Port	0.15~80	3V	80	A	Pass
CAN Port	0.15~80	3V	80	A	Pass

Note:

The performance criteria are classified into four groups:


A ---- Normal performance within the specification limits;

B ---- Temporary degradation or loss of function or performance which is self-recoverable;


C ---- Temporary degradation or loss of function or performance which requires operator intervention or system reset;

D ---- Degradation or loss of function which is not recoverable due to damage of equipment (components) or software, or loss of data.

3.4.4 Test Setup




Radio-frequency Conducted Disturbance Immunity Test Input DC Port Set-Up –Front View



Radio-frequency Conducted Disturbance Immunity Test Signal Port Set-Up –Front View

3.5.4 Test Setup



Magnetic Fields Test Set-Up –Front View

/

END OF THE TEST REPORT